

CARTRIDGE SYSTEM



CARTRIDGE TANK™ PLUMBING SCHEMATIC

Provisions should be made to install three ball valves (Valves 1, 2, & 3 in the diagram) for a bypass loop around the Cartridge Tank. These ball valves should allow for water to be turned off to the Cartridge Tank for future cartridge replacement, and allow for system bypassing should other service be required. Be sure to observe local plumbing codes.

Drains should be considered in the plumbing of the Cartridge Tank as per the diagram. Opening a drain valve will allow for the backwashing or flushing of the cartridge. Closing the inlet and outlet valves and opening a drain valve will relieve pressure on the Cartridge Tank for cartridge replacement.

